

**Annexure-1 (Revised)**

Sl.No.	Section	Page No.	Clause No.	Clause Description	Bidder's Queries	RECPDCL Response
1	NIT	8	1.5	The Scope of works of the contractor under the contract shall involve end to end delivery of the commissioned plant to RECPDCL, which will include (but not limited to) the development of land, design, engineering, procurement of equipment and material, testing at manufacturer's works, packing and forwarding, transportation, supply, receipt and unloading at site, storage, insurance at all stages, associated civil works, electrical works, services, permits, licenses, installation, erection, testing, commissioning.	We would request you to kindly elaborate on the underlined scope i.e. " Development Of Land"	Leveling, Cutting of bushes, Boundary etc. Is in the scope of bidder. Please refer clause 4.4.1.5 and 4.4.1.6 under detailed technical requirement
2	Conditions of Contract	47	3.13.2	The Employer shall enter into Right to Use/Lease Agreement with the Implementing Agency/SPIA within the timeline and in accordance with the provisions of the RfS document. Within 07 days of getting possession/allotment of land from the SPIA, the Employer shall handover the land to the contractor	We would request you to kindly confirm if encumbrance free access to land shall be provided to contract on effective date of contract i.e LOA issuance date.? Also kindly include the provision that in case there is delay in handing over of land by employer to EPC contractor, the contract completion time shall be equitably adjusted.	The request is not relevant as the Zero date is the date of handing over of land to the contractor
3	Conditions of Contract	49	3.17.2	Submission of DPR for the Project	We understand that the DPR is prepared by the developer for the approval by board of the company /investors. Hence the preparation of DPR	Submission of DPR which includes Shop Drawings, Execution

					should be excluded from the scope of EPC contractor.	Plan etc. Tender condition prevails.
4	Conditions of Contract	50	3.17.2	Commissioning of Entire Plant in line with the procedure elaborated in Standard PPA document : ZD + 300	Reading the referred clauses in conjunction, we have noticed certain inconsistency. Hence we would request you to kindly clarify the following:	Total Commissioning Time is 10 Months from Zero date.
5	Conditions of Contract	5	3	a) 10 months from the date on which letter issued to the contractor for handing over of land by RECPDCL which shall be based on handing over of the land by SPIA/LSPDCL (Lucknow Solar Power Development Corporation Limited) on as is where is basis.	1. Kindly clarify if the commissioning is 10 months OR 300 days from the Zero date? 2. Zero date is the date of issuance of LOA? 3. SCOD is not reflected in the L1 chart under Clause 3.17.2. Kindly clarify. 4. In SCOD same as commissioning of plant?	Zero date is the date of handing over of the land to the contractor.
6	Conditions of Contract	63	3.38.2	COMMISSIONING After all the works in respect of Pre-commissioning are completed and in the opinion of the Contractor, the Facilities is ready for Commissioning, the Contractor shall so notify the Engineer-in-charge in writing. The commissioning of the facilities shall be carried out in the presence of the Engineer-in-charge or his representative(s) in accordance with RfS Document, in line with the commissioning procedure of Implementing Agency and as per procedures detailed in this	Kindly confirm as under: 1. Since RfS is applicable between the employer and relevant agency hence kindly exclude RfS documents from these specifications and eventually RfS needs to be excluded from contract as well. 2. Kindly confirm that in case there is an inconsistency between RfS and the tender spec, which one should prevail? 3. We would request you to kindly elaborate the definition of commissioning as a part	1. Tender Condition prevails. 2. In case of any inconsistency, RECPDCL shall have sole discretion on the matter. 3. Tender Condition prevails. 4. Please refer clause 3.3.3

				Specifications. The Authorized representative of Implementing agency /State Nodal Agency may also witness or validate the commissioning procedure at site	of the specification itself instead of cross reference to RfS.	
7	Part – D Detailed Technical Requirement	201/304	4.4.2. 2.2	MMS Structure	Please clarify, can contractor use stainless steel structure instead of hot dip galvanizing. If yes, Please specify specifications.	Tender Condition prevails.