

Amendment-1

Date: 08-Sep-2017

Ref: NIT No. RECPDCL/TECH/JKPDD/e-Tender/2017-18/1755 Dated: 21.08.2017.

Sr. No.	RFP Document Reference (Clause No., Page No.)	Existing Clause	Amended Clause
1	Scope of Work (Amended clause will apply in whole NIT)	Construction of 66/11kV Substation, 66 kV line, 11kV line, Augmentation of existing 66/11 kV substation, installation /Augmentation of distribution transformers along with other associated works in Leh circle on full turnkey basis under R-APDRP Part-B.	Construction of 11 kV line, installation / Augmentation of Distribution Transformers along with other associated works in Bandipore & Sumbal towns on turnkey basis under R-APDRP Part-B. (Details covers in attached Annexure-1)
2	Electricity Act		The Jammu & Kashmir Electricity Act, 2010 will be applicable.
3	GCC 1.1 (ee) Page 134	Time for Completion: Till 31.03.2018	Time for Completion: Till 28.02.2018
4	Governing Law & its Jurisdiction	Governing laws and courts of New Delhi shall have exclusive jurisdiction.	Governing laws and courts of J&K state shall have exclusive jurisdiction.
5	List of eligible scheduled commercial private Indian banks		J&K Bank also included
6	Qualification of the bidder engagement, Page no.34 to 37	1.01 Technical: (I) Part I: Supply, Erection, Testing & Commissioning of New/Augmentation of existing 33/11KV or 66/11 KV power substation1 and new/Augmentation of its associated 33 or 66 KV Lines.	Clause deleted
7	Pre-qualification criteria – Part A:	(III) Part III: Combined Part of Part-I & II above	
8	BoQ/Price Bid		Revised BoQ/price bid containing technical specifications is attached as Annexure-1
9	Pre-dispatch inspection		JKPDD representative shall also involved in all the pre dispatch inspection of all materials along with RECPDCL officer.
10	Arbitration and Conciliation Act		J&K Arbitration and Conciliation Act, 1997 shall be applicable.
11	Danger board (Volume-I : Section-VII, Scope of Works) Clause no.11,Page no.248	Danger board should be in bi-lingual languages (local language and English)	Danger board should be in bi-lingual languages (Urdu and English)
12	Pre-bid meeting & venue		Pre-bid meeting will be again held on 14.09.2017 (11:00 AM) at Srinagar, J&K. Venue: Office of Chief Engineer, Project Wing Kashmir, Power Development Department House no.9-Post office Lane, Behind Mubarik Hospital Hyderpora, Srinagar, J&K-190001

Technical Specifications			
Clause No	Activity	Observations/Comments	Remarks
2 -a	A.New 33KV Lines	9.1 meter long /280 KG PCC Poles shall be amended to 9 meter long /300 KG PCC Poles	Pole designation and type shall be adopted as in the BoQ
2=b		11 M long steel Tubular poles of Designation 540 SP 52 (IS 2713, Pt I, II, III shall be amended to 11 M long steel Tubular poles of Designation 410SP 56 (IS 2713, Pt I, II, III 1980)	
2-c		13 M long steel Tubular poles of Designation 540 SP 72 (IS 2713, Pt I, II, III shall be amended to 13 M long steel Tubular poles of Designation 410SP 72 (IS 2713, Pt I, II, III 1980)	
a	D.New 11 KV Lines	8 m/140 kgs PCC Poles shall be amended to 8 m/250 kgs PCC Poles	
d		11 M long Steel Tubular poles of Designation 540 SP 52 (IS 2713, Pt I, II, III 1980) shall be amended to 11 M long steel Tubular poles of Designation 410SP 56 (IS 2713, Pt I, II, III 1980)	
e		9 M long Steel Tubular poles of Designation 540 SP 28 (IS 2713, Pt I, II, III 1980) shall be amended to 9 M long steel Tubular poles of Designation 410SP 33 (IS 2713, Pt I, II, III 1980)	
1-a	E.Distribution Transformer Substations	BPL household not being a beneficiary under RAPDRP and is deleted	
21.1.1	Service Cable	Service Cable: 2.5 mm twin core Al (un-armoured) PVC insulated cables shall be amended to 2Cx16sqmm Al armoured	

Note: All the Technical Specifications modified in BoQ to be adopted by the bidders.

This is issue with the approval of Competent Authority

Please contact for further queries (if any):

Phone: 0120-4383775/783

Email: jkpdd.projects@recpdcl.in