

Amendment-2 dated: 14.08.2018, Ref: NIT No. 1876 dated: 02.08.2018

S. No.	Clause No./Page No.	Existing Provisions	Proposed Revised Provisions
1	Clause No. 3(iii), Section-V, Page No. 13 of NIT document	Bottom section of pole shall be galvanized as per BIS standard throughout, internally and externally, up to the level which goes inside the earth. Galvanization shall be done in accordance with IS: 4759 & IS: 2629 with latest amendments.	Bottom section of pole shall be galvanized as per BIS standard throughout, internally and externally including base plate. Galvanization shall be done in accordance with IS: 4759 & IS: 2629 with latest amendments.