

NIT No. RECPDCL/TECH/CED/e-Tender/2017-18/136 Dated: 13.04.2017
Prebid Meeting on 21.04.2017

Pre-Bid Clarification-1

Dated:26.04.2017

| S. No. | Vendor | Item | Technical Specifications as per RFP | Queries / Modifications / Changes Suggested | Clarification |
|--------|----------------------------------|--|--|--|---|
| 1 | M/s Valmont Structures Pvt. Ltd. | - | - | Earth wire mentioned three different types at three different locations i.e. GSS 7/2.24mm. OPGW-48core and GSS 7/3.15mm. Kindly confirm the type of earth wire to be used in the designs. | Earth wire of GSS 7/3.15mm required to be used in design |
| 2 | M/s Valmont Structures Pvt. Ltd. | SECTION-IV Scope of work, Clause no.3 page no.10 | Total no of Monopole Tower: 28 No (C+9 type: 4 Nos, C+6 type: 23 Nos, C+3 type: 1 Nos). Considering span length of 150 Mtr. | As per monopole specification there are three types of poles, Suspension (0-2) and Tension (0-30) & (30-60) with +3/6/9/12m extensions but as per detail scope of work C+3(2)/+6(2)/+9(5) types are required with 150m span. Request you to confirm span and BOQ of poles along with required extensions. Also if there is any special requirement for line tapping. | As per NIT |
| 3 | M/s Valmont Structures Pvt. Ltd. | Clause no.5 of Technical specification of Monopole | STEEL: The steel to be used shall be conforming to IS-2062 (grade E-350 B0 or equivalent) | Steel requirement as per IS 2062 E350. We would like to use ASTM Gr-65 (Min. Ys 450Mpa) for pole shaft and Gr-50 (Min. Ys 345Mpa) for base plate. | Steel requirement as per IS 2062 or higher grade can be used |
| 4 | M/s Valmont Structures Pvt. Ltd. | - | - | There is no deflection limits are mentioned in the tender; we shall follow pole deflections as per CBIP manual. (5% under ultimate load case and 2% for safety normal load case) | Yes bidder may follow CBIP manual or any other relevent indian standard for deflection limits |
| 5 | M/s Valmont Structures Pvt. Ltd. | - | - | Please Also confirm whether ladder and handrail arrangement is to be provided (there is no mention in the tender) for the tender. | Not required |

Note: Rest of the bid will be evaluated as per tender specifications