

25.04.2023

GeM Bid No: GEM/2023/B/3221030 dated: 03.03.2023

Amendments II

	Reference Clause or Pg. No.	Bidder's Query	Clause as per RFP	Clarification to bidder	Nature of comments
1.	APPENDIX- A.1 TAMPER CONDITIONS FOR SINGLE PHASE WHOLE CURRENT METER	For Magnetic field >10mT, clause existing in Magnet section and for microwaves, the strength/range is not defined and this is non-standard destructive tamper requirement. Request you to kindly provide required details for microwaves or remove the same.	In Microwave Tamper, Any higher frequency magnetic waves, microwaves > 10mT.	Deleted	Amendment