

Pre-Bid Queries for NIT No.RECPDCL/TECH/DGPS-GED/e-Tender/2015-16/512 Dated: 04.06.2015

S.No.	Description	Agency	RECPDCL Remark	Change Category
1	The date of submission is too close from prebid meeting. Request you to extend by another 15 days	NSG	Not acceptable.	No Change
2	For 14,000 Line Km of network the geographical area of over 3700 Sq.Kms seems large compared to other Towns in India. Is there an anomaly in area or is there a problem with the network length. Let us know exact geographical area and network length?	NSG	Estimated length and area as mentioned in the tender document is correct as per information provided by utility.	Clarrification
3	Please indicate total Line Km for both HT and LT networks	NSG	The estimated length for each voltage level as intimated by utility for information and ready reference of bidder only as annexure given below. However, this may vary as actual	Clarrification
4	Please indicate number of poles in Marmagoa, Margao and Mapusa to arrive at the costs involved in asset painting	NSG	This information is not available.	Clarrification
5	The timelines for completion of tasks are too sharp. Considering the impending monsoon season it would be even more difficult to meet the timelines. Work can commence in parallel in all the Towns. However, we request for a minimum of 10 months time period to complete the survey of the network of over 14,000Km spread over 3,700 Sq. Kms	NSG	As per request from all bidder, Completion timelines for Landbase creation, 33 KV asset mapping, 11 KV asset mapping is extended for 15 days and Timelines for LT network and consumer indexing is extended for 30 days from the timelines as given in the tender documents. All other terms and condition of the tenders documents remain unchanged. However, it is very important to complete the delivery before the dates.	Major change
6	We are currently in the middle of executing similar works in Karnataka and Kerala hence we can not submit the completion certificates. PO / WO of similar works may therefore be considered under eligibility criteria.	NSG	Not acceptable.	No Change
7	Payment terms are too harsh hence we request you to consider to have the following payment terms changed. 1. Mobilisation advance 20% against submission of PBG 2. Network Survey : 50% on completion of Survey and approval and balance 25% on completion of asset Painting 3. Consumer Survey: 50% on submission of Data and balance 25% on data integration	NSG	Not acceptable.	No Change
8	Please consider to change the financial bid format as below for the following items: 1. DGPS Survey for HT and LT to be quoted in Line Km 2. Pole Painting to be quoted per Pole unit	NSG	Not acceptable. However, network length as available is shared for information and reference only.	Clarrification

9	What type of code needs to be painted for poles carrying multiple networks (LT+LT, HT+LT, 33+HT+LT).	COORD Technologies	Asset numbering concept is geographical based and no relation with network over them as already explained in tender document. All HT and LT pole shall be numbered as HT and LT criteria respectively irrespective of multiple network.	Clarrification
10	PROFORMA OF SCHEDULE OF RATES : For serial no 2 and 3 unit of measurement give as feeder and for serial no 4 unit of measurement given as DT. We are requesting please check possibilities to change as Linear KM for serial no 2,3 and 4.	COORD Technologies	Not acceptable. However, network length as available is shared for information and reference only.	Clarrification
11	AOI : Not specified whose responsibility	Last Peak Accounts	Satellite imagery is available with us and same will be provided as per your area for further creation of Landbase.	Clarrification
12	GCP Collection	Last Peak Accounts	This shall comply the guidelines as mentioned in the tender document.	Clarrification
13	Important land Marks and Other misc. features: Not mentioned clearly	Last Peak Accounts	This shall comply the guidelines as per SRS.	Clarrification
14	Presence of Lines man(GSEB) is required	Last Peak Accounts	Assistance of lineman from GED shall be arranged depending upon the availability but such things shall not impact the timelines as mentioned.	Clarrification
15	DGPS instrument Accuracy: (+/-) 1 to 5 mtr.	Last Peak Accounts	This shall comply the guidelines as mentioned in the tender document.	Clarrification
16	U/G survey is required?. If required, what methodology to be adopted?	Last Peak Accounts	This shall comply the guidelines as mentioned in the tender document.	Clarrification
17	What will be the approx. Length of the line to be covered. PI specify	Last Peak Accounts	Please refer Annexure.	Clarrification
18	Master Data base" GSEB will provide, Required for verification from master data .	Last Peak Accounts	Whatever data is available, the same shall be provided as per requirement.	Clarrification
19	Door to door survey of consumer location using DGPS/GPS,;LAT/LONG value of each consumer to be captured from field?	Last Peak Accounts	Yes.	Clarrification
20	Approval of the activities : REC or Bidder, In the activities it is mentioned GSEB and in payment RECPDCL	Last Peak Accounts	It is very important that data created and final deliveries shall be accepted by GED and RECPDCL.	Clarrification
21	LD Clause: 10% per month on item wise or subject to 30% maximum. Can LD clause be relaxed.	Last Peak Accounts	Not acceptable	No Change
22	Back Office: In GOA only, Can we have a small back office instead of full set of team at GOA.	Last Peak Accounts	It depends upon bidder. It is must to complete the terms and conditions, specifications and timelines of tender document.	Clarrification
23	10% advance agst Advance BG.	Last Peak Accounts	Not Acceptable	No Change
24	Delivery of data in .dwg/.shp format & before migration to GIS software. PI. Clarify	Last Peak Accounts	delivery to be provided in the specified format and same must be updated to GIS system too.	Clarrification
25	Data for migration to GIS software, Is the responsibilities of RECPDCL, PI. Clarify	Last Peak Accounts	Delivery shall be provided in specified format and all errors/ changes, if any while migration must be corrected for successful migration of data to GIS.	Clarrification

26	Satellite Image: Required at the begging of the work, Pl. Clarify	Last Peak Accounts	It shall be provided.	Clarrification
27	Painting of Assets as per codification logic, Asset painting shall be carried out for the Trfs/ Poles/FP/Towers. Not to any other assets, Pl. Clarify	Last Peak Accounts	It shall be done on assets as mentioned in the tender document and SRS.	Clarrification
28	Painting of Assets as per codification logic, In case of HT,EHT,LT first two or three digit will be reserved for painting. In case of HT+LT pole, what will be the methodology. Pl. Clarify	Last Peak Accounts	Asset numbering concept is geographical based and no relation with network over them as already explained in tender document. All HT and LT pole shall be numbered as HT and LT criteria respectively irrespective of multiple network.	Clarrification
29	Demarcation of admin boundary, In land base data model, on field demarcation of admin boundary is the responsibilities of the Vendor/Client, Pl. clarify	Last Peak Accounts	Information shall be provided as available.	Clarrification
30	1. RAPDRP work will done only three town namely. Marmagoa. Margao, Mapusa. Asset painting will be done only one town –PAJIM	Last Peak Accounts	Bidder shall have complete ownership for final delivery of data as per specifications of tender documents and SRS for three towns as mentioned in tender document. However, for Panjim, only asset allocation and painting shall be carried out. All network details shall be provided by us.	Clarrification
31	For pole painting –PAJIM town – recpdcl will be share which format data(shp file or PGDB or PDF drawing feeder wise soft copy / hard copy) –please clarify	Last Peak Accounts	We may share shp or Pdf format as per availability.	Clarrification
32	Pre qualify criteria- as per -27 . form II. (there are mention Delhi/NCR office – is it mandatory? Please clarify	Last Peak Accounts	It is not mandatory to have office in Delhi/NCR.	Very Minor Change
33	Evaluation Methodology: We request you to mention the selection process either it is quality and cost based selection (QCBS) or least cost selection	N Arc Consulting	Submitted bidder shall undergo eligibility criteria and after fulfilling the same, bid shall be shortlisted for financial opening. However, award of contract shall undergo as per terms and consitions of tender document. RECPDCL may opt for reverse option if required.	Clarrification
34	Change the Payment terms and condition	N Arc Consulting	Not acceptable	No Change
35	Extension of submission of Bids	N Arc Consulting	Not acceptable	No Change
36	Delivery of Data in soft and Hard Copy. How many hard copy to be provided.		As final delivery to be accepted by GED. Hard copy of the data for delivery can be considered as two Copies. However, same may be additional as per requirement.	Clarrification
37	Unit Price for collection of GCP		In the price bid, bidder shall provide the unit price for collection of GCP separately. In case, GCP is not collected or collected less than the specified in tender, then pro rata amount from respective price line item shall be adjusted.	Clarrification

Annexure : Network Ckt Length

Town	33 kV Ckt Length in Km	11 kV Ckt Length in Km	LT Ckt Length in Km
Mapusa	318	1416	4147
Marmagaon	122	362	1016
Margao	477	1664	4264