

Pre-Bid Queries for NIT No. RECPDCL/TECH/UPS-GED/e-Tender/2014-15/2061 dated 30.01.2015

S. No.	Firm Name	Item	Page No. / Clause No.	Parameter	Technical Specifications as per RFP	Queries / Modifications / Changes Suggested	RECPDCL Remarks
1	Hitachi	2/5 KVA UPS	11	Network attachable UPS	Support for NMS and EMS	Is the requirement only for RS 232 port or SNMP connection?	It is SNMP connection through RJ45.
2	Hitachi, PowerOne	2/5 KVA UPS	11	Warranty on UPS & Battery	> Comprehensive warranty for 3 years + 2 years AMC	OEM's provide only 2 years warranty on batteries. So, it is suggested to either modify the requirement to "comprehensive warranty for 5 years"	Bid will be evaluated as per warranty clause mentioned in RFP.
3	Hitachi	2/5 KVA UPS	<New>	Type of Battery	-	add "VRLA (Value Regulated Lead Acid Battery"	Bid will be evaluated as per clause mentioned in RFP.
4	Hitachi	2/5 KVA UPS	<New>	Make		CPRI approved battery	Bid will be evaluated as per clause mentioned in RFP.
5	Hitachi	2/5 KVA UPS	12	Payment Criteria	50% payment shall be released against successful completion of deliveries at the delivery location	This is on the lower side. It is suggested to increase it to 70% payment on successful completion of deliveries at the delivery location	Payment terms will be as mentioned in RFP.