Date: 05.03.2022 Tender Ref No. RECPDCL/JKPDD/AMI/21-22/2329 Dated: 06.01,2022					
Pre-Bid Queries - 2 After issuance of Amendment 1					
S.No.	Page No./ Clause No.	Specifications as per RfP	Amendments		
1	Clause No 8.1.1 RF Solution Provider eligibility criteria:	T.7 Interoperability: The RF Solution provider have successfully integrated their NIC/ Communication module with at least 3 Indian smart meter manufacturers, meeting the QR. "As per clarification (S No 76) bidder has to undergo POC with 3 Indian Smart Meter Manufacturers meeting the QR	The RF Solution provider have successfully integrated their NIC/Communication module with at least 2 Indian smart meter manufacturers, meeting the QR.		
2	Page No. 318/ Annexure T: Specification of Polycarbonate Seals	Bidders are requested to manufacture 05 sample seals of each colour as per the RECPDCL specification and submit (non-returnable) the sample along with bid for approval. These samples to be submitted in Meter Testing Lab & intimated to RECPDCL.	Deleted		
3	Form-14 Table-1 : Bill of Materials and Services for Smart Meters	Point 2.7: Ground Mounted 9:1 Smart Meter Cabinet Box for 5% of connections.	The design of the box to be provided at the time of detailed engineering by the bidder based on site conditions. The required material shall be Sheet Moulded Compound		
4	Specification of Wedge connectors: Amendment-1	Amendment-1: Vendor Registration: The vender registered in GUVNL or its any subsidiary for supply of clamps and connectors of any size shall be entitled for bid submission. Proof of vender registration shall be submitted along with the bid.	Deleted		
5	Specification of Wedge connectors: Amendment-1	Amendment-1: 10. Drawings and sample: 11. Quality Assurance Plan	Deleted		
6	Page No. 21/ Annexure – I: Methodology of Proof of Concept	RFP/AMI-IA Contract: Amendment 1 - The bidder shall demonstrate PoC with 2 nos. of meters each of 3 different Indian Smart Meter manufacturers and offered HES	The bidder shall demonstrate PoC with 2 nos. of meters each of 2 different Indian Smart Meter manufacturers and offered RF Solution		
7	In the Amendment-1 : Annexure A Clause No. D	Formula for Aluminium conductor XLPE insulated 1.1kV power cables is given: P = Po + AIF (AL – Alo) + CCFA1 (CC – Cco) + FeF (Fe – Feo)	As per IEEMA Circular date 01/11/2017, the PV Formula for Aluminium conductor XLPE insulated 1.1kV power cables: P= Po + AlF (AL – Alo) + XLFAL(CC-Cco)+ CCFAl (PVCc – PVCco) + FeF (Fe – Feo). The same is enclsoed herewith.		
8	Amendment: DB Box specs Point No, 4:Sl No. 5	In General Technical Requirements of SL No. 5 - Incoming cable size as 4Cx50 Sq.mm size Un armoured.	Incoming cable size as 4Cx35 Sq.mm size Un armoured.		
9	Section 3: Clause 27.1	Quantity variation	The quantity variation for 3-ph Whole Current Meters shall be -20%+ 100%. In case the quantity variation of the individual items is beyond the limit specified above, the unit rates for the quantity beyond the said limit, shall be mutually agreed based on prevailing market rates as may be fair and reasonable.		

10	Section 2, Clause 1 & Section 3, ITB Clause 15.13	Addendum	In addition to the compliance to mentioned Order No. 11/05/2018-Coord. dated 17 September 2020 in RfP and MoP Order No.: A-1/2021-FSC-Part(5) dated 16th Nov. 2021 and any amendments issued thereafter, whereever applicable in RfP.
11	General	Revised Financial bid excel	The revised financial bid excel has been uploaded on tender wizard. The Quanity and UoM of Financial bid shall be final.
12	Bank details	Addendum	RECPDCL Bank details for submission of EMD is as follows: Name of Bank & Branch : IDFC First Bank Limited Wholesale Banking Outlet Express Building, 2nd Floor , 9-10 Bahadur Shah Zafar Marg, New Delhi-110002 Bank Account Name : REC Power Development and Consultancy Limited Bank Account Number : 10000697415 Bank IFSC Code No : IDFB0020101
13	Section 3: Clause 25- Successful/Selected Bidder	Clarification	For removal of doubt, it is clarified that the expression 'different AMI-IAs'/ 'different bidders' appearing or referred to explicitly or by implication in Clauses ITB 25.3, ITB 25.4, ITB 25.5 and ITB 25.6 shall mean such AMI-IAs/ bidders who do not have a conflict of interest or are not deemed to have a conflict of interest under the provisions of Clauses ITB 3.1 / ITB 3.2.